

Dyness



Not yet tested. Current models do not support FDCan; new hardware will.

Use with the HS19 (650 - 1000 V DC)

Current models do not fit. The Tower lines top out at 576 V, below the HS19 minimum of 650 V. Awaiting new hardware.

Manufacturer links

- Homepage: [Dyness](#)
- HV range: [Residential High Voltage ESS](#)
- Tower series: [Tower \(T7 - T21, 192 - 576 V\)](#)
- Newer lines: Tower Pro (7.68 - 23.04 kWh), Tower S3 (7.1 - 255.72 kWh)

Compatibility status

- Test status: TBD
- FDCan support: current models no; new hardware will support it

Setup guide



To be written once a model is tested.

From:

<https://www.victronenergy.com/live/> - **Victron Energy**

Permanent link:

https://www.victronenergy.com/live/hv_battery_compatibility:dyness

Last update: **2026-06-12 14:41**

