

VRM Portal alarms and monitoring

The VRM Portal constantly monitors and watches over your system and can also inform you by email if something is amiss. There are four categories of monitoring:

- The no data alarm: monitors the connection between the Portal and the Victron installation
- Automatic alarm monitoring: monitors a predefined list of parameters on all connected products
- Geofence: monitors location (requires a Color Control GX with a USB-GPS)
- User configurable alarms

The screenshot displays the VRM Portal Settings interface. At the top, there is a navigation bar with icons for Live feed, Solar yield, Consumption, Batteries, Advanced, and Settings. Below this, the main content area is divided into a left sidebar and a main panel. The sidebar contains links for General, Tags, Site summary, Set location, Set geofence, Advanced tab setup, Users, Alarm rules, and System overview. The main panel shows the 'Settings' page with an 'Alarm log' button. Under the 'Alarm rules' section, there are three active alarms: 'No data alarm' (Alarm armed), 'Automatic alarm monitoring' (Only alarms), and 'VE.Bus System' (VE.Bus state). An 'Add alarm' link is also present. Below the alarm rules, there is a section titled 'Users that receive alarm mails for Matthijs Thuis'. This section lists two users: Johannes Boonstra (jboonstra@victronenergy.com) and Matthijs Vader (mvader@victronenergy.com). Each user has a toggle switch to enable or disable email notifications. The 'Save all settings' button is located at the bottom left of the main panel.

Alarm Category	Status	Action
No data alarm	Alarm armed	+
Automatic alarm monitoring	Only alarms	+
VE.Bus System	VE.Bus state	+



[Add alarm](#)

Users that receive alarm mails for Matthijs Thuis	
Johannes Boonstra jboonstra@victronenergy.com	No
Matthijs Vader mvader@victronenergy.com	Yes

[Save all settings](#)

1. No data alarm

Typically used for land-based installations, such as off-grid farms and telecommunication sites.

 **No data alarm**
Alarm armed 

Enter the amount of extra time on top of the existing logging interval that is allowed before sending an alarm. For example, a logging interval of 15 minutes is 900 seconds. With a no-data-alarm-timeout of 600 seconds, the system will send an alarm after it has not received any new data for 1500 seconds.

No data alarm

Armed

|||



Notify after (minutes)

5

2. Automatic alarm monitoring

Monitors a predefined list of parameters on all connected products. With this feature, it is no longer necessary to manually configure alarm rules for all the different parameters. An email will be sent if any of the parameters listed below enters an Alarm state, and optionally for Warnings too. A recovery email will be sent if the parameter returns to its normal value.

You can set the monitor to send an email alert for alarms only, for warnings and alarms, or disable it entirely. The default for new sites is Only alarms:

 **Automatic alarm monitoring**
Only alarms 

Monitors a predefined list of parameters on all connected products.

☐ Disabled

☒ Only alarms

☐ Warnings and alarms

2.1 Predefined list of monitored parameters

2.1.1 VE.Bus products (Multi, Inverter and Quattro)

- VE.Bus state

- VE.Bus Error
- Temperature alarm
- Low battery alarm
- Overload alarm

2.1.2 BMV and Lynx Shunt VE.Can

- High voltage alarm
- Low voltage alarm
- High starter-voltage alarm
- Low state-of-charge alarm
- Low battery temperature alarm (BMV-702 only)
- High battery temperature alarm (BMV-702 only)
- Mid-voltage alarm (BMV-702 only)
- Low fused-voltage alarm (Lynx Shunt only)
- High fused-voltage alarm (Lynx Shunt only)
- Fuse blown alarm (Lynx Shunt only)
- High internal-temperature alarm (Lynx Shunt only)
- Low starter-voltage alarm (Lynx Shunt only)

2.1.3 Solar charger

- Charger fault
- Charge state
- Equalization pending
- Alarm condition
- Low voltage alarm
- High voltage alarm
- Error code

2.1.4 Skylla-i charger

- Charger fault
- Charge state
- Error
- Low voltage alarm
- High voltage alarm

2.1.5 Lynx Ion BMS

- Error code
- Error

3. User configurable alarms

Advanced rules, including hysteresis can be configured for all parameters available in the VRM

database.

3.1 How to properly configure high, low and their hysteresis

To understand what the hysteresis is, consider the following example: you want an alarm as soon as the battery voltage drops below 10 volt. And only when it rises again above 11.5 volts, you want the alarm to clear. These 11.5 V is the hysteresis.

A properly configured alarm rule meets the following criteria:

- The low hysteresis should be equal to or higher than the low alarm threshold
- The high hysteresis should be equal to or lower than the high alarm threshold
- The low hysteresis should be lower than the high alarm threshold (otherwise a high alarm will be triggered as soon as the low alarm is cleared)
- The high hysteresis should be higher than the low alarm threshold

Note November 2014: after rereading the exact meaning of hysteresis, I see that this is the concept. And not the right word for the value at which to clear an alarm. We'll rename these items on the and then also this text shortly: Low hysteresis → Clear low alarm above High hysteresis → Clear high alarm below

3.2 Receiving and alarm on mains failure

This is an alarm typically wanted in a backup system.


To set it up, configure an alarm on the VE.Bus State.

Set the Inverter state as 'Armed'.

4. Geofence

Typically used for rental vehicles and boats. The example below shows a Geofence that will give an alert when the boat leaves the lake. An alarm will also be generated when the location data is no longer being received, for example when the GPS receiver is unplugged. Use this in combination with the No data alarm for full coverage.

Create a geofence on the map below. To receive an alarm when your site is outside the created geofence, set the toggle switch below the map to on.



~~DISQUS~~

From:
<https://www.victronenergy.com/live/> - **Victron Energy**

Permanent link:
https://www.victronenergy.com/live/vrm_portal:alarms?rev=1479162813

Last update: **2016-11-14 23:33**

