

Certificate of Conformity

By the product certificate number

No. 2622/0478-C/E2-CER

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark: **victron energy**
BLUE POWER

Contract number: **803947**
803948

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated Power	8.0 kVA / 6.4 kW	10.0 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated input Voltaje	187-250 V	220-265 V	187-250 V
Rated Voltage		DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V	
Rated Frequency		50 Hz	
Firmware version	2682558	2683558	2684558
Number of phases		Single Phase (L/N/PE)	
Isolation transformer		Yes	

Is in compliance with the standard:

- **Technical Prescription C10/11 of Synergrid. Edition 2.4 (15.10.2025). (1)**

(1) Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate supersedes certificate no. 2622/0478-C-E1-CER.

This certificate is first issued on 29th January 2024.

This certificate is valid until the 5th July 2028.

Madrid, 11th June 2026

Daniel Arranz Muñiz
Certification Manager

