

Certificate of Conformity

By the product certificate number

No. 2622/0478-C-CER

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark: **victron energy**
BLUE POWER

Contract number: **802190**

It is certified that the product:

Type of product: Inverter/charger with UPS functionality

Models:		MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V
Rated characteristics:	Rated Power	8.0 kVA / 6.4 kW	10.0 kVA / 8 kW
	Rated Voltage	AC input: 187-250 V _{ac}	AC input: 187-250 V _{ac}
		DC input: 38-66 V _{dc}	DC input: 38-66 V _{dc}
	Rated Frequency	AC output: 220-240 V _{ac}	AC output: 220-240 V _{ac}
		DC output: 48 V _{dc}	DC output: 48 V _{dc}
	Firmware version	50 Hz	50 Hz
	Number of phases	2621502	2627502
Isolation transformer	Single Phase	Single Phase	
	Yes	Yes	

Is in compliance with the standard:

- **Technical Prescription C10/11 of Synergrid. Edition 2.2 (15.03.2021) (*)**

(*) Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 5th of July 2023. This certificate is valid until the 5th of July 2028.

Madrid, 5 of July of 2023

Daniel Arranz Muñiz
Certification Manager



S SGS Tecnos, S.A.U. C/ Trespaderna, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions.
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).
This document cannot be reproduced partially

