



A P P R O V A L S ®

## Certificate of Suitability

### \*Addendum\*

**Certificate No.:** SAA181339

**Date of Issue:** 11 March 2026

**Regulatory Definition:** Non-Prescribed  
**Product Description:** Battery Inverter

**General Modification:**

Standard changed from AS IEC 62477.1:2024 to IEC 62040-1:2017 Inc A1:2021.

**Additional Models**

MultiPlus-II 48/4k5/55-32 230V

**Trade Name**

Victron Energy

**Rating/Marking**

Energy Storage Port Ratings:  
48Vdc, Charge/Discharge current 55/95A

Grid Input Port Ratings:  
230Vac 50/60Hz 32A 0.8 to 0.8 p.f.

Independent Supply Output Port Ratings:  
Pass through mode: 230Vac 50/60Hz 32A 0.8 to 0.8 p.f.  
Inverter mode: 230Vac 50/60Hz 17A 4.0kVA

Protective Class: I  
Over Voltage Category: AC III  
Topology: Isolated  
Ingress Protection: IP21  
Operating Temperature Range: -20°C to +65°C  
Software Version: 2623495


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 11-03-26 181339/4  
Page 1 of 3



A P P R O V A L S ®

# Certificate of Suitability

**Additional Models**

MultiPlus-II 48/4k5/55-32 230V GX

**Trade Name**

Victron Energy

**Rating/Marking**

Energy Storage Port Ratings:  
48Vdc, Charge/Discharge current 55/95A

Grid Input Port Ratings:  
230Vac 50/60Hz 32A 0.8 to 0.8 p.f.

Independent Supply Output Port Ratings:  
Pass through mode: 230Vac 50/60Hz 32A 0.8 to 0.8 p.f.  
Inverter mode: 230Vac 50/60Hz 17A 4.0kVA

Protective Class: I  
Over Voltage Category: AC III  
Topology: Isolated  
Ingress Protection: IP21  
Operating Temperature Range: -20°C to +65°C  
Software Version: 2623495

MultiPlus-II 48/6k5/100-50 230V

Victron Energy

Energy Storage Port Ratings:  
48Vdc, Charge/Discharge current 100/135A

Grid Input Port Ratings:  
230Vac 50/60Hz 50A 0.8 to 0.8 p.f.

Independent Supply Output Port Ratings:  
Pass through mode: 230Vac 50/60Hz 50A 0.8 to 0.8 p.f.  
Inverter mode: 230Vac 50/60Hz 26A 4.0kVA; 4,0kW

Protective Class: I  
Over Voltage Category: AC III  
Topology: Isolated  
Ingress Protection: IP21  
Operating Temperature Range: -20°C to +65°C  
Software Version: 2623495


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 11-03-26 181339/4  
Page 2 of 3



A P P R O V A L S ®

## Certificate of Suitability

**Additional Models**

MultiPlus-II 48/6k5/100-50 230V GX

**Trade Name**

Victron Energy

**Rating/Marking**

Energy Storage Port Ratings:  
48Vdc, Charge/Discharge current 100/135A

Grid Input Port Ratings:  
230Vac 50/60Hz 50A 0.8 to 0.8 p.f.

Independent Supply Output Port Ratings:  
Pass through mode: 230Vac 50/60Hz 50A 0.8 to 0.8 p.f.  
Inverter mode: 230Vac 50/60Hz 26A 4.0kVA; 4,0kW

Protective Class: I  
Over Voltage Category: AC III  
Topology: Isolated  
Ingress Protection: IP21  
Operating Temperature Range: -20°C to +65°C  
Software Version: 2623495


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 11-03-26 181339/4  
Page 3 of 3