

Certificate of Conformity

By the product certificate number:

No. 2622/0478-L-CER

Issued to:

License holder: **Victron Energy, B.V.**
De Paal 35, 1351 JG Almere, The Netherlands

Trademark:



It is certified that the product:

Type: **Inverter/charger with UPS functionality**

Family: **Multiplus-II**

Models:

		Multiplus-II 48/15000/200-100 230V	Multiplus-II 48/10000/140-100 230V	Multiplus-II 48/8000/110-100 230V
Technical data:	AC rated input power	12.0 kVA / 12.0 kW	8.0 kVA / 8.0 kW	6.4 kVA / 6.4 kW
	AC rated input voltage	187-250 V _{AC}	187-265 V _{AC}	187-265 V _{AC}
	AC rated output power	15.0 kVA / 12.0 kW	10.0 kVA / 8.0 kW	8.0 kVA / 6.4 kW
	AC rated output voltage	220-240 V _{AC}	230 V _{AC}	230 V _{AC}
	AC rated current (In / Out)	100 A _{AC} / 54 A _{AC}	100 A _{AC} / 36 A _{AC}	100 A _{AC} / 29 A _{AC}
	Rated frequency (In / Out)	50/60 Hz	50/60 Hz	50/60 Hz
	DC rated voltage (In / Out)	48 V _{DC} (38-66 V _{DC}) / 48 V _{DC}	48 V _{DC} (38-66 V _{DC}) / 48 V _{DC}	48 V _{DC} (38-66 V _{DC}) / 48 V _{DC}
	DC rated current (In / Out)	350 A _{DC} / 200 A _{DC}	235 A _{DC} / 140 A _{DC}	188 A _{DC} / 110 A _{DC}
	Software control version	2619560	2627560	2621562
	Number of phases	Single-phase	Single-phase	Single-phase
	Isolation Transformer	Yes	Yes	Yes

Is in compliance with the standard:

- **IEC 62477-1:2022 + COR1:2024**, "Safety requirements for power electronic converter systems and equipment. Part 1: General".

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-30 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 23rd April 2026.

This certificate is valid until 23rd April 2031.

Madrid, 23rd April 2026

Daniel Arranz Muñiz
Certification Manager

