

Prüfbescheinigung *Declaration of Conformity*

Antragsteller:
Applicant:

Victron Energy B.V.
De Paal 35
1351 JG Almere Haven
Netherlands

Produkttyp:
Product type:

Battery inverter/charger

Modell:
Model:

MultiGrid-II 48/3000/35-32
MultiPlus-II 48/3000/35-32

Leistung:
Rating:

Input: 48Vdc, 75Amax (discharge), 35Amax (charge)
Output: 230V, 1Ph + N + PE, 50Hz, 11Amax (discharge), 16Amax (charge), 2,4kW

Ein repräsentatives Prüfmuster des oben genannten Modells bestand die Prüfung nach:
A representative test sample of above stated model passed the tests according to:

Norm:
Standard:

IEC/EN 62040-1:2008 + A1:2013
IEC/EN 62109-1:2010
IEC/EN 62109-2:2011

Berichtsnummer:
Report no:

17PP264-01_0; 17PP264-02_0; 17PP264-03_0

Zertifikatsnummer:
Certificate no:

18-208-00

Ausstelldatum:
Date of issue:

2018-07-20



Raphael Rader

