



APPROVALS®

## Certificate of Suitability

\*Addendum\*

**Certificate No.:** SAA160334

**Date of Issue:** 2 August 2018

**Class Description:** Non-Declared

**Product Description:** Bi-directional AC/DC Converter for use in a battery storage system

**Additional Models**

Quattro 48/15000/200-100/100

**Description**

Similar to Multiplus 12/3000/120-16 except for additional BF relay, output relay, capacitors and rated:

Input:-

AC: 187-250V~ 45-55Hz 100/100A

DC: 38-66Vdc, 350A

Output:-

AC: 225-235V~ 50Hz 53A

DC: 52.8-57.6Vdc 200A


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 02-08-18 160334/8