



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA160334

Date of Issue: 4 July 2016

Class Description: Non-Declared

Product Description: Bi-directional AC/DC Converter for use in a battery storage system

Additional Models

Description

Quattro 48/5000/70-100/100

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:

Input:-

AC: 187-250V~ 45-55Hz 100/100A

DC: 38-66Vdc 118A

Output:-

AC: 225-235V~ 50Hz 18.5A

DC: 52.8-57.6Vdc 70A

Quattro 48/5000/70-100/100-S

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:

Input:-

AC: 187-250V~ 45-55Hz 100/100A

DC: 38-66Vdc 118A

Output:-

AC: 225-235V~ 50Hz 18.5A

DC: 52.8-57.6Vdc 70A

Quattro 48/8000/110-100/100

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:

Input:-

AC: 187-250V~ 45-55Hz 100/100A

DC: 38-66Vdc 188A

Output:-

AC: 225-235V~ 50Hz 28.5A

DC: 52.8-57.6Vdc 110A


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 04-07-16 160334/6