



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA160334

Date of Issue: 24 May 2016

Class Description: Non-Declared

Product Description: Bi-directional AC/DC Converter for use in a battery storage system

Additional Models	Description
Multiplus 12/3000/120-50	Similar to Multiplus 12/3000/120-16 except for multi-board design in lieu of one-board design and rated AC input 50A.
Multiplus 24/3000/70-16	Similar to Multiplus 12/3000/120-16 except for different transformer and rated DC input 19-33V 125A, DC output 26-4-28.8V 70A.
Multiplus 24/3000/70-50	Similar to Multiplus Multiplus 24/3000/70-16 except for multi-board design in lieu of one-board design and rated AC input 50A.
Multiplus 48/3000/35-16	Similar to Multiplus 12/3000/120-16 except for different transformer and rated DC input 38-66V 65A, DC output 52.8-57.6V 35A.
Multiplus 48/3000/35-50	Similar to Multiplus Multiplus 48/3000/35-16 except for multi-board design in lieu of one-board design and rated AC input 50A.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-05-16 160334/2