



America

# CERTIFICATE

No. U10U 087546 0006 Rev. 01

**Holder of Certificate:** **Victron Energy B.V.**

De Paal 35  
1351 JG Almere  
THE NETHERLANDS

**Certification Mark:**



**Product:** **Rechargeable lithium-ion battery**

**Tested according to:** UL 2054:2021/R:2022-03

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing, Certification, Validation and Verification Regulations (TCVVR)".

**Test report no.:** 713405405

**Date,** 2026-03-05

( Benedikt Pulver )



America

# CERTIFICATE

No. U10U 087546 0006 Rev. 01

**Model(s):**

LiFePO4 Battery 25.6 V/ 100 AH NG  
LiFePO4 Battery 25.6 V/ 200 AH NG  
LiFePO4 Battery 12.8 V/ 100 AH NG  
LiFePO4 Battery 12.8 V/ 200 AH NG  
LiFePO4 Battery 51.2 V/ 100 AH NG

**Parameters:**

Li-Ion Battery					
Test item particulars	25.6V / 100Ah	25.6V / 200Ah	12.8V / 100Ah	12.8V / 200Ah	51.2V / 100Ah
Battery type	Secondary				
Classification of installation and use	Stationary application				
Recommended charging method	CCCV				
Discharge current	100 A	200 A	100 A	200 A	100 A
Specified final min. voltage	22.4 V	22.4 V	11.20 V	11.20 V	44.8 V
Upper limit charging voltage per cell	3.65 V				
Maximum charging current	100 A	200 A	100 A	200 A	100 A
Charging temperature	+5°C to 50°C				
Configuration	8S1P	8S2P	4S1P	4S2P	16S1P
Mass of battery	19 kg	37 kg	9 kg	19 kg	37 kg

**Conditions of Acceptability:**

When installing all requirements of mentioned test specification(s) and conditions of acceptability must be fulfilled.

ZERTIFIKAT ◆ CERTIFICATE ◆ 認 證 證 書 ◆ CERTIFICADO ◆ CERTIFICAT