



America

# CERTIFICATE

No. U10U 087546 0006 Rev. 00

**Holder of Certificate:** **Victron Energy B.V.**

De Paal 35  
1351 JG Almere  
THE NETHERLANDS

**Certification Mark:**



**Product:** **Rechargeable lithium-ion battery**

**Tested** **UL 2054:2021/R:2022-03**

**according to:**

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing, Certification, Validation and Verification Regulations (TCVVR)".

**Test report no.:** 713380652

**Date,** 2025-09-23

( Benedikt Pulver )



America

# CERTIFICATE

No. U10U 087546 0006 Rev. 00

**Model(s):** LiFePO4 Battery 25.6V/200AH NG

## Parameters:

LiFePO4 Battery 25.6 V/200 Ah NG

Lynx Smart BMS 500 NG (M10)  
9-60 VDC / 500 A

Lynx Smart BMS 1000 NG (M10)  
9-60 VDC / 1000 A

Rated Voltage (V)	25.6
Degree of Protection	IP 65
Construction	Portable
Supply connection	Permanent connection to fixed wiring
Operation mode	Continuous operation
Weight (kg)	37
Software revision number(s) for functional safety	V1.01

## Conditions of Acceptability:

When installing all requirements of mentioned test specification(s) and conditions of acceptability must be fulfilled.