

CERTIFICATE OF CONFORMITY

Certificate No.: LC26-6384-1

Date Issued: July 13, 2026

Project No.: 26-6384

Certification System: Type 3
(ISO / IEC 17067)

Client No.: LC1231751

Applicant: Victron Energy B.V.
De Paal 35
1351 JG Almere
Netherlands



Issued by: 
Certification Manager

Products:

- Inverter/Charger
- Model: MultiPlus-II 48/5000/70-95 120V
- Ratings:
 - AC input: 90 – 140 VAC, 95 A, 55 – 65 Hz
 - AC output: 120 VAC, 33 A, 60 Hz, PF=0.8
 - DC input: 38 – 66 VDC, 110 A
 - DC output: 48 VDC, 70 A

Applicable requirements:

- UL 458 6th Edition

Conditions of acceptability:

- None

General Note:

- Refer to LC Listing Report no. 10.00.26-6384-1_Rev.0