



Certificate of Conformity

Certificate: 17030-1S

Master Contract: LC 1231751

Project: 17030

Date Issued: August 30, 2018

Issued to: Victron Energy B.V.
De Paal 35
1351 JG Almere Haven
The Netherlands

Certification System Type 3
(ISO / IEC Guide 67)

The products listed below are eligible to bear the LabTest Certification Mark with adjacent indicators 'C' and 'US', and the subject area as shown below.



Issued by:

Certification Manager

PRODUCTS

- Inverter
- Models: MultiPlus 12/3000/120-50 120V
MultiPlus 24/3000/70-50 120V
- Ratings:

Model number	DC IN Input Voltage range; Input current max	AC OUT Grid output Voltage; Output current	AC IN (range)	DC OUT	Apparent nominal output power (Sn)	Active nominal output power (Pn)
MultiPlus 12/3000/120-50 120V	9.5-17Vdc 250A	120Vac, 60Hz, 21A	95-140Vac, 55-65Hz, 50A	13.2-14.4Vdc 120A	3kVA	2.4kW
MultiPlus 24/3000/70-50 120V	19-33Vdc 125A	120Vac, 60Hz, 21A	95-140Vac, 55-65Hz, 50A	26.4 – 28.8Vdc, 70A	3kVA	2.4kW

APPLICABLE REQUIREMENTS & SUBJECT AREA

- UL 1741: 2016 (Ed.2)
- CAN/CSA C22.2 No. 107.1-16 (Ed.4)

CONDITIONS OF ACCEPTABILITY

- None

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable CSA and UL Standards respectively. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.