

Victron Energy B.V

De Paal 35 1351
JG Almere-Haven,
The Netherlands

Kaufbeuren, 21.08.2018

TO WHOM IT MAY CONCERN

This is to confirm that the following products

Victron MultiGrid-II 48/3000/35-32 and Victron MultiPlus-II 48/3000/35-32

are subject to testing and certification according the South African low voltage grid code NRS 097-2-11:2017.

The certificate can be issued after confirmation of presence of a successful EMC Report as required in section 4.1.13.3 in the range of 30kHz to 148,5kHz.

All other related tests to the overmentioned standard are successfully completed, the test results are described in the test report number 17PP264-07-D.

With best regards

Jürgen Seegger

Deputy Manager Grid Code Compliances